FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
★ ★ ★ ★ ★
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ **Date: 09-03-2015**

TEST REPORT ON WET MIX MACADAM MIX
(GRADATION TEST)

Sub: To conduct Gradation test on Wet Mix Macadam (WMM) Mix.
{Project*:Asphalting to road at 2nd Main Chamundeshwari Layout in Ward No.10(Doddabommasandra), of Vidyaranyapure Sub-Division}

Ref.: Letter No. Testing/BUB/2014-15, dated 06-03-2015

Sample supplied to lab by Sri.Shivkumar N.M, Contractor, Bangalore.

Report required for: Assistant Executive Engineer, Vidyaranyapure Sub-Division. BBMP, Bangalore.

TEST RESULTS

1. Gradation Test:

TABLE 1.1

Sieve Size mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Specified Limits as per MoRTH Specifications, IV Revision-2001
53.00	**100.00**	100
45.00	**96.70**	95-100
26.50	**---**	-
22.40	**75.60**	60-80
11.20	**46.20**	40-60
4.75	**37.30**	25-40
2.36	**23.60**	15-30
0.600	**18.90**	8-22
0.075	**3.50**	0-8

*As Furnished by Client

The Results relate only to the items tested

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

9/3/15
Dr. MANJESH .L
ME (Civil Engg .). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail manjesh@gmail.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/

Date: 27-03-2015

TEST REPORT ON BITUMINOUS MIXES
(BITUMEN EXTRACTION TEST & GRADATION TEST)

Sub: Testing of Bitumen Premix Sample (Semi Dense Bituminous Concrete-SDBC).
{Project*:Asphalting to road at 2nd Main Chamundeshwari Layout in Ward No.10(Doddabommasandra), of Vidyaranyapure Sub-Division}

Ref.: Letter No. Testing/BUB/2014-15, dated 23-03-2015

Sample supplied to lab by: Sri.Shivkumar N.M, Contractor, Bangalore.

Report required for: Assistant Executive Engineer, Vidyaranyapure Sub-Division. BBMP, Bangalore.

TEST RESULTS:

7. The bitumen content obtained after subjecting the sample for Bitumen Extraction test = **5.02 %**
8. **Gradation Test** :

Sieve Size, mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Gradation requirement as per Table 500-15 of MORTH Specifications-2001 (Grading – 2)
13.2	**100**	100
9.5	**96.60**	90—100
4.75	**45.70**	35—51
2.36	**35.20**	24—39
1.18	**20.80**	15—30
0.3	**16.30**	09—19
0.075	**3.60**	03—08

* As furnished by Client.

The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg .). Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail. manjeshl@yahoo.com

FOR QUALITY & EXCELLENCE IN HIGHER EDUCATION
Accredited by NAAC

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ Date: 07-03-2015

TEST REPORT ON WET MIX MACADAM MIX
(GRADATION TEST)

Sub: To conduct Gradation test on Wet Mix Macadam (WMM) Mix.
{Project*:Asphalting to road at Ganesh Temple road in Chamundeshwari Layout in Ward No.10 of Vidyaranyapure Sub-Division}

Ref.: Letter No. Testing/BUB/2014-15, dated 04-03-2015

Sample supplied to lab by: Sri.Aswathnarayana Anjanappa, Contractor, Bangalore.

Report required for: Assistant Executive Engineer,
Vidyaranyapure Sub-Division.
BBMP, Bangalore.

TEST RESULTS

1. Gradation Test:

TABLE 1.1

Sieve Size mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Specified Limits as per MoRTH Specifications, IV Revision-2001
53.00	**100.00**	100
45.00	**97.30**	95-100
26.50	**---**	-
22.40	**72.50**	60-80
11.20	**45.10**	40-60
4.75	**36.00**	25-40
2.36	**23.70**	15-30
0.600	**18.80**	8-22
0.075	**3.60**	0-8

*As Furnished by Client

The Results relate only to the items tested

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Compus
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg) Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರಗಳ
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ,
ಯಲಹಂಕ ವಲಯ,
ಬೃ. ಬೆಂ. ಮ. ಪಾ., ಬೆಂಗಳೂರು-97

Phone Off: 080-22961935 / 1946
E-mail: centrans9@gmail.com

BANGALORE UNIVERSITY
DEPARTMENT OF CIVIL ENGINEERING

JNANA BHARATHI
BANGALORE - 560 056

BUB/CTE/2014-15/ Date: 23-03-2015

TEST REPORT ON BITUMINOUS MIXES
(BITUMEN EXTRACTION TEST & GRADATION TEST)

Sub: Testing of Bitumen Premix Sample (Semi Dense Bituminous Concrete-SDBC).
{Project*:Asphalting to road at Ganesh Temple road in Chamundeshwari Layout in Ward No.10 of Vidyaranyapure Sub-Division}

Ref.: Letter No. Testing/BUB/2014-15, dated 19-03-2015

Sample supplied to lab by: Sri.Aswathnarayana Anjanappa, Contractor, *Bangalore.*

Report required for: Assistant Executive Engineer,
Vidyaranyapure Sub-Division.
BBMP, Bangalore.

TEST RESULTS:

5. The bitumen content obtained after subjecting the sample for Bitumen Extraction test = **5.06 %**
6. **Gradation Test :**

Sieve Size, mm	Percent by Weight passing the Sieve from the sample supplied (Obtained Gradation)	Gradation requirement as per Table 500-15 of MORTH Specifications-2001 (Grading – 2)
13.2	**100**	100
9.5	**96.50**	90—100
4.75	**44.00**	35—51
2.36	**35.10**	24—39
1.18	**17.00**	15—30
0.3	**16.60**	09—19
0.075	**3.90**	03—08

* As furnished by Client.
The Results relate only to the items tested.

G.R. HARISH
Professor
Department of Civil Engineering
Jnana Bharathi Comp...
BANGALORE UNIVERSITY
Bangalore-560 056.

Dr. MANJESH .L
ME (Civil Engg) Ph D MISTE.MIRC
Associate Professor
Department of Civil Engineering
Bangalore University Jnanabharathi Campus
BANGALORE- 560 056
e- mail: manjeshl@yahoo.com

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಧಿಕಾರಿ
ವಿದ್ಯಾರಣ್ಯಪುರ ಉಪ ವಿಭಾಗ
ಯಲಹಂಕ ವಲಯ,
ಬೃ. ಬೆಂ. ಮ. ಪಾ. ಬೆಂಗಳೂರು-97